

# Technical Data Sheet


Pressure / Temperature / Humidity / Air Velocity / Airflow / Sound level

# Differential pressure transmitter **CP 114 – CP 115**

# **KEY POINTS**

- Ranges from -500/+500 mbar to -2000/+2000 mbar (according to models)
- Configurable intermediary ranges
- 0-10 V or 4-20 mA output, active, power supply 24 Vac/Vdc (3-4 wires) or 4-20 mA output, passive loop, power supply from 16 to 30 Vdc (2 wires)
- ABS V0 housing, IP65, with or without display
- "1/4 turn" system mounting with wall-mount plate
- · Housing with simplified mounting system

# FEATURES OF THE HOUSING



Material: ABS V0 as per UL94 Protection: IP65 Display: LCD 10 digits. Size: 50 x 17 mm Height of digits: Value: 10 mm; Unit: 5 mm Connections: safety Ø6.2 mm Cable gland: for cables Ø8 mm maximum Weight: 143 g


# **TECHNICAL FEATURES**

Measurement units	mbar, inWG, mmHG, PSI, mmH <sub>2</sub> O, daPa, hPa, kPa
Accuracy*	±1.5% of reading ±3 mbar
Response time	1/e (63%) 0.3 s
Resolution	1 mbar; 0.1 inWG; 1 mmHG; 1 mmH <sub>2</sub> O; 1 hPa; 10 daPa; 0.1 kPa; 0.1 PSI
Autozero	Manual with push-button
Type of fluid	Air and neutral gases
Overpressure tolerated	CP114: 1400 mbar; CP115: 4100 mbar
Conditions of use (°C/%RH/m)	From 0 to +50°C. In non-condensing condition. From 0 to 2000 m.
Storage temperature	From -10 to +70°C
	·

\*All the accuracies indicated in this technical datasheet were stated in laboratory conditions, and can be guaranteed for measurements carried out in the same conditions, or carried out with calibration compensation.

# PART NUMBER

To order, just add the codes to complete the part number:



Measuring range 4: -500/+500 mbar 5: -2000/+2000 mbar O: with display N: without display

Power supply / Output A: Active – 24 Vac/Vdc – 0-10 V or 4-20 mA P: Passive – 16/30 Vdc – 4-20 mA


#### Example: CP 114 – AO Pressure transmitter measuring range -500/+500 mbar, 0-10 V or 4-20 mA active, with display



CE

TECHNICAL SPECIFICATIONS					
Output / Supply	<ul> <li>active sensor 0-10 V or 4-20 mA (alim. 24 Vac/Vdc ±10%), 3-4 wires</li> <li>passive loop 4-20 mA (power supply 16/30 Vdc), 2 wires</li> <li>common mode voltage &lt;30 VAC</li> <li>maximum load: 500 Ohms (4-20 mA) / minimum load: 1 K Ohms (0-10 V)</li> </ul>				
Consumption	2 VA (0-10 V) or 0.6 VA (4-20 mA)				
European directives	2014/30/EU EMC; 2014/35/EU Low Voltage; 2011/65/EU RoHS II; 2012/19/EU WEEE				
Electrical connection	Screw terminal block for cables from 0.05 to 2.5 mm2 or from 30 to 14 AWG Carried out according to the code of good practice				
Communication to PC	USB-mini DIN cable				
Environment	Air and neutral gases				

# CONNECTIONS



# ELECTRICAL CONNECTIONS – as per NFC15-100 standard


For CP114/115 - AO models and CP114/115 - AN

models with 0-10 V or 4-20 mA output - active, 4 wires :


This connection must be made by a qualified and trained technician. To make the connection, the transmitter must not be energized.



To make a 3-wire connection, before powering up the transmitter, please connect the output ground to the input ground. See drawing below.



#### For CP114/115 - PO models and CP114/115 - PN models with 4-20 mA output - passive:



#### > Autozero

To perform an autozero, unplug the 2 pressure connections tubes and press the "Autozero" key.


When an autozero has been performed, "On" green light turns off then turns on, and on transmitters equipped with a display, "autoZ" is displayed.


#### Configuration



To configure the transmitter, it must not be energized. Then, you can make the settings required, with the DIP switches (as shown on the drawing below). When the transmitter is configured, you can power it up.

To configure the transmitter, unscrew the 4 screws from the housing then open it. DIP switches allowing the different settings are then accessible.





#### Measuring range settings – left DIP switch

To set a measuring range, put the 1, 2 and 3 on-off switches as indicated in the table below.

	1 2 3 4 Combination 1		1 2 3 4 Combination 2		1 2 3 3 4 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5		1 2 2 3 4 Combination 4		1 2 3 4 Combination 5	
Type of transmitter	CP114	CP115	CP114	CP115	CP114	CP115	CP114	CP115	CP114	CP115
mbar	100	500	200	750	300	1000	400	1500	500	2000
inWG	40.0	200.0	80.0	300.0	120.0	400.0	160.0	600.0	200.00	800.0
kPa	10.0	50.0	20.0	75.0	30.0	100.0	40.0	150.0	50.0	200.0
PSI	2.0	10.0	4.0	15.0	6.0	20.0	8.0	30.0	10.0	40.0
mmHg	80	400	160	600	240	800	320	1200	400	1600
mmH <sub>2</sub> O	1000	5000	2000	7500	3000	10 000	4000	15 000	5000	20000
daPa	1.0	5.0	2.0	7.5	3.0	10.0	4.0	15.0	5.0	20.0
hPa	100	500	200	750	300	1000	400	1500	500	2000

• Measuring ranges of the CP114 transmitter on the ±500 mbar range according to the measurement unit.

• Measuring ranges of the CP115 transmitter on the ±2000 mbar range according to the measurement unit.

#### Example:

• From 0 to 750 mmH<sub>2</sub>O, measuring range is 750 mmH<sub>2</sub>O.

• From -500 mbar to +500 mbar, measuring range is 1000 mbar.

#### > Standard range / central zero setting – *left DIP switch*

To set the type of measuring range, put the on-off switch 4 as indicated beside:

Example 0-100 mbar: Full scale / 0 Central zero



(0 / 100 mbar) (-50 mbar / 0 / +50 mbar)

Configurations	Full scale	Central zero		
Combinations				



Please follow carefully the combinations beside with the DIP switch. If the combination is wrongly done, the following message will appear on the display of the transmitter "CONF ERROR". In that case, you will have to unplug the transmitter, place the DIP switches correctly, and then power the transmitter up.

# > Output setting - right DIP switch (CP114/115 - AO and CP114/115 - AN models)

To set the type of analogue output, please put the on-off switch of the output as shown beside.

Configurations	4-20 mA	0-10 V
Combinations		1 2 3 4

#### > Units setting – *right DIP switch*

To set a measurement unit, put the on-off switches 2, 3 and 4 of the units as shown in the table below.

Configurations	mbar	inWG	kPa	PSI	mmHG	$\rm mmH_2O$	daPa	hPa
Combinations	1 2 2 3 3 4 9 4 9 4 9 4 1 4 1 4 1 4 1 4 1 4 1 4 1	1 2 1 2 3 4 1 4 1 4 1 4 1 4 1 4 1 4 1 4 1 4 1 4	1 2 2 3 3 4 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9	1 2 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4	1 2 2 3 4 4 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1 2 2 3 4 1 4 1 4 1 4 1 4 1 4 1 4 1 4 1 4 1 4	1 2 2 3 3 4 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1 2 2 3 4 4 5 6 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7

# CONFIGURATION VIA LCC-S SOFTWARE (option)

An easy and friendly configuration with the software!


You can configure your own intermediary ranges.

Caution : the minimum difference between the high range and the low range is 20.

For example, it is possible to set the instrument from -20 to 0 mbar, from 0 to +20 mbar, or from -10 to +10 mbar... • To access the configuration via software:

- Set the DIP switches as shown beside. Nota : the on-off switch 1 of the right DIP switch can be in
- any position (selection of the analogue output 0-10 V or 4-20 mA)
- Connect the cable of the LCC-S to the connection of the transmitter.
- Please refer to the user manual of the LCC 100 to make the configuration.

The configuration of the parameters can be done either with the DIP switch or via software (you can not combine both solutions).



Once returned to KIMO, required waste collection will be assured in the respect of the environment in accordance with European guidelines relating to WEEE.

#### www.kimo.fr

afaq
150 9001
Qualité
AFNOR CERTIFICATION

EXPORT DEPARTMENT Tel : + 33. 1. 60. 06. 69. 25 - Fax : + 33. 1. 60. 06. 69. 29 e-mail : export@kimo.fr Distributed by :

 Configuration via PC

 1
 1

 2
 2

 3
 3

 4
 4

 Left DIP switch
 Right DIP switch